



















Hydraulic control valves are direct - sealing diaphragm valves activated by pipeline pressure. When in the control chamber pressure is equal to the pipeline pressure the rubber diaphragm closes the valve. The spring in the upper side of diaphragm helps valve to close regardless of pressure and flow conditions.

Expanding the pressure from control chamber ,valve opens.

The valve's only moving part is its diaphragm.


TYPES AND DIMENSIONS OF BASIC VALVE

MATERIAL		CAST IRON GG 25 - DUCTILE IRON GGG 40				
mm	Inch	CODE	THREADED	THREADED ANGLE	FLANGED	FLANGED ANGLE
50	2	V 50-50	 4 Kg	 5 Kg	 8,5 Kg	 9,2 Kg
65	2 ½	V 65-50	 4,3Kg	 5,3 Kg	 10,5 Kg	 11,5 Kg
80	3	V 80-50			 11 Kg	 12,5 Kg
80	3	V 80-80			 15 Kg	
100	4	V 10-50			 13 Kg	
100	4	V 10-10			 20 Kg	
125	5	V 12-10			 24 Kg	
150	6	V 15-15			 45 Kg	
200	8	V 20-15			 75 Kg	
250	10	V 25-20			 130 Kg	
300	12	V 30-30			 145 Kg	





MATERIAL LIST

1	Body	D.I GGG 40
2	Cover	D.I GGG 40
3	Diaphragm	NBR
4	Spring seat	POLYAMID
5	Spring	AISI 302
6	Nuts and bolts	Coated steel



FLOW CHART



PS - PR - V valve remains the upstream pressure constant and reduces the downstream pressure regardless of pressure and flow - rate fluctuations.

PS - PR -V valves are direct-sealing diaphragm valves, activated automatically by a 2 - way upstream pressure sustaining pilot and 2 - way downstream pressure reducing pilot.

When pressure exceeds the preset level, the sustaining pilot allows valve to open fully .
At the same time pressure reducing pilot controls downstream pressure and remains it constant.

DESCRIPTION

NORMES

Flanges	EN 1563 / EN 1092-2
Thread	BSP / NPT
Pressure	PN 10/16
Coating	Powder epoxy 250 µm DIN 30677
Testing	EN 12266-1